



Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

Packaged Product: K4601			
KEROSENE DEODORIZED			
Test	Target/UOM	Range	Result
VIS @ 40 DEG C, ASTM D-0445, CST	CST		1.90 CST
Sample ID			
Tested 04/12/23			
Tester TBUR			
Recorded 04/12/23			
GRAVITY, API @ 60 DEC F	46.0 DEG F	43.0 - 49.0	46.8
Sample ID			
Tested 04/12/23			
Tester TBUR			
Recorded 04/12/23			
GRAVITY IN POUNDS/GAL @ 60F	LB/GAL		6.616
Sample ID			
Tested 04/12/23			
Tester TBUR			
Recorded 04/12/23			
FLASH PMCC,C	MIN 71C DEG C		82.0
Sample ID			
Tested 04/12/23			
Tester TBUR			
Recorded 04/12/23			
FLASH PMCC,F	MIN 160F DEG F		204
Sample ID			
Tested 04/12/23			
Tester TBUR			
Recorded 04/12/23			
POUR POINT,F	-40F DEG F		-25
Sample ID			
Tested 04/12/23			
Tester TBUR			
Recorded 04/12/23			
COLOR (SAYBOLT)	MIN +28 COLOR		30
Sample ID			
Tested 04/12/23			
Tester TBUR			
Recorded 04/12/23			
WATER CONTENT	MAX 500PPM %		30 PPM
Sample ID			
Tested 04/12/23			
Tester TBUR			
Recorded 04/12/23			



Aqua Solutions, Inc.
6913 Highway 225
Deer Park, TX, 77536
281/479-2569
Certificate of Analysis / QC Results
Customer PO # :

DISTILLATION,IBP F	MIN 400F DEG F	434
Sample ID		
Tested	04/12/23	
Tester	TBUR	
Recorded	04/12/23	
DISTILLATION,5% RECOVERED,F	DEG F	441
Sample ID		
Tested	04/12/23	
Tester	TBUR	
Recorded	04/12/23	
DISTILLATION,50% RECOVERED,F	DEG F	448
Sample ID		
Tested	04/12/23	
Tester	TBUR	
Recorded	04/12/23	
DISTILLATION,95% RECOVERED,F	DEG F	467
Sample ID		
Tested	04/12/23	
Tester	TBUR	
Recorded	04/12/23	
DISTILLATION,DRY POINT,F	DEG F	474
Sample ID		
Tested	04/12/23	
Tester	TBUR	
Recorded	04/12/23	
DISTILLATION,END POINT,F	MAX 514F DEG F	477
Sample ID		
Tested	04/12/23	
Tester	TBUR	
Recorded	04/12/23	
SPECIFIC GRAVITY @ 60/60 DEG F	SPEC GRAVITY	0.7936
Sample ID		
Tested	04/12/23	
Tester	TBUR	
Recorded	04/12/23	

Lot # 310101
Made 04/11/23

Quality Manager